



Janet T. Mills
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Bruce A. Van Note
COMMISSIONER

January 7, 2019
Subject: Intersection Improvements
State WIN: 023030.00
Location: **West Bath**
Amendment No. 1

Dear Sir/Ms:

The following question has been received:

Question: Is the existing electric service single phase or three phase? What's the voltage?

Response: No electric service currently exists. Per Traffic Signal Note 5, on page 11 of the plan set, the Contractor is to "INSTALL NEW 120V/240V POWER SERVICE FOR TRAFFIC SIGNALS AND LIGHTING."

Consider these changes and information prior to submitting your bid on **January 15, 2020**.

Sincerely,

George M. A. Macdougall P.E.
Contracts & Specifications Engineer